

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1209:227

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: System Sensor, Unincorporated Div of Honeywell International Inc, 3825 Ohio Ave., St. Charles
IL 60174
Contact: Trish Linhart (630) 377-6580 FAX (630) 377-7245

DESIGN: Models 5601, 5602, 5621, and 5622 combination fixed-temperature and rate-of-rise type
and Models 5603, 5604, 5623, and 5624 fixed-temperature mechanical heat detectors.
Refer to listee's data sheet for detailed product description and operational
considerations.

RATING:	Models	Fixed Temperature	Electrical
	5601	135°F	6-125V AC, 3A
	5602	194°F	"
	5603	135°F	6-28V DC, 1A
	5604	194°F	"
	5621	135°F	125V DC, 0.3A
	5622	194°F	"
	5623	135°F	250V DC, 0.1A
	5624	194°F	"

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature/electrical rating, and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible fire alarm control units.
Refer to listee's Installation Instruction Manual for details.

10-07-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 7, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**